



Procurement Office

October 1, 2018

ADDENDUM NO. 1

GCSC ITB NUMBER: #4-2018/2019
GCSC ITB TITLE: UPS System for WKGC FM-HD Transmitter Site

The above numbered solicitation is amended as follows to address proposer's questions.

Except as provided herein, all terms and conditions of the solicitation, including changes made by all prior addenda (if any), remain unchanged and in full force and effect.

Question 1 My question is about the monitoring, what exactly is the scope for this. Is only SNMP/Mobdus TCP IP configuration?

Answer The scope is to be able to remote monitor the status of the UPS and the Generator. The design must include all equipment and software needed for remote monitoring and must be supplied and installed as part of this project.

Firms must acknowledge receipt of this addendum by signing and returning this addendum with your sealed document.

FAILURE TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. (See page 2)

Tonia E. Lawson, CPPB, CPP, CPPM, CGPP, CPDW
Executive Director of Procurement & Auxiliary Services



Complete this portion and include in your proposal submittal.

RECEIPT ACKNOWLEDGED:

COMPANY: _____ SIGNATURE: _____

TITLE: _____ DATE: _____